

FIRE SAFETY CERTIFICATE

REF: EFS/2022-2023/33/52

Date: 18.04.2024

Certified that the Gold Field Public School Chhainsa Ballabgarh Faridabad Pin code 121004 comprised of ground floor and 1st, 2nd, 3rd floor occupied by Gold Field Public School have complied with the fire prevention and fire safety requirement in accordance with fire services rule and verified by the concerned in the persence of management and that the building is fit for occupancy upto classes XII with effect form a period of one year in accordance with safety rule.

The Equipments such as ABC stored pressure, mechanical foam (AFFF) and water CO2 are ISI marked and are Hydraulically tested at the pressure of 25kgf/cm² type fire extinguishers at the pressure of 254 kgf/cm².

Hence these are working conditriion

The deatails are as follows:

11(Eleven) number of fire extinguishers (5kg capacity), 4 (Four) number of fire extinguishers (4kg capacity) have been fixed.

Signature with Seal

THANK YOU AND BEST REGARDS
FIRE SAFETY YOURS
FOR EXCELLENT FIRE SERVICE



REF: EFS/2023-2024/33/ 52

M/s. Gold field Public School
Chamisa Landebor

TEST CERTIFICATE

THIS IS TO CERTIFY THAT THE FOLLOWING FIRE EXTINGUISHERS HAVE BEEN
SOLD / REFILLED TO ABOVE MENTIONED CLIENT.

THE EQUIPMENTS SUCH AS ABC STORED PRESSURE, MECHANICAL FOAM (AFFF)
AND WATER CO2 ARE ISI MARKED AND ARE HYDRAULICALLY TESTED AT THE
PRESSURE OF 25 KGF/CM2 AND CO2 TYPE FIRE EXTINGUISHERS AT THE
PRESSURE OF 254 KGF/CM2.

HENCE THESE ARE IN WORKING CONDITION


THIS IS VALID FOR ONE YEAR FROM DATE OF ISSUE.

THE DEATAILS ARE AS FOLLOWS:

- (i) ABC Type fire extinguish 5 kg Capacity 11 no
- (ii) ABC Type fire extinguish 4 kg Capacity 4 no

THANK YOU AND BEST REGARDS

FIRE SAFELY YOURS
FOR EXCELLENT FIRE SERVICE


(AUTHORIZED SIGNATORY)